#### **CONSTRUCTION:**

Radiant Ceiling Panels shall be made of highest quality steel casing. Front panel shall be painted with textured powder coated finish. Electric Resistance graphite element is fixed between dielectric material and insulation. Two inches of insulation is compressed to one inch by back panel to minimize upward heat loss and radiant efficiency. Radiant panels shall have 36" pre-wired flexible cable for easy installation and wiring connections.

#### **INSTALLATION:**

CP Series shall be designated as 2x2 or 2x4 size. All panels are 1" thick. The size shall be nominal dimension to be manufactured to fit drop ceiling systems. Standard units will fit regular "T" Bar frame. For tegular or trim line or other frame sizes, special construction is required. RCP Series shall be used in recess mounting applications. RCP Series shall be 2" less in width to recess between nominal 24" center ceiling joists. RCP Series shall be complete with recess frame for finished construction.

#### **ACCESSORIES:**

Surface mounting frames shall be optional for surface mounting the CP Series.

#### **OPTIONS:**

Silk-screening the front surface to match some acoustic tiles is available.

# Markel Products Company


## CP & RCP Series Radiant Ceiling Panel Heaters

### SUBMITTAL DATA, CP & RCP SERIES

AGENT	PROJECT	ENGINEER	DATE

TAG			
QTY.			
MODEL NUMBER			
VOLTS / PHASE			
THERMOSTAT			
OPTIONS			
NOTES			





Markel Products Compan